

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

CLAY-ROANE PSD (PROCIOS DISTRICT), WV3300806

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 1/1/2025 and 3/31/2025, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Failure to Monitor/Report Disinfectant By-Product Precursors (TOC and/or Alkalinity)	1/1/2025 to 3/31/2025

What happened? What is being done? (Describe corrective action)

A clerical error was made during the submission of this sample. It was submitted as a finished,
treated sample, but should have been an untreated water sample. The operator literally checked
the wrong box on the paper work. The sample was still tested and well within standards.
Operators are undergoing in-house refresher training in sampling procedures.

For more information, please contact Crystal Adkins at (304) 548-5209
(Contact name) (Phone number)
Or 1100 Elk River Rd, Prociou, WV 25164
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **CLAY-ROANE PSD (PROCIOS DISTRICT)**

State Water System ID #: WV3300806

Date Distributed: 7/1/2025